

LIGHTING FIXTURE SCHEDULE

| MOUNTING | FLUORESCENT | INCANDESCENT/HID | INPUT | | REMARKS | |
|------------------|---|------------------|-----------------------------|-------|---------|---|
| | | | VOLTS | WATTS | | |
| RECESSED | FR | R | | XR | | |
| CEILING/SURFACE | FC | C | | KC | | |
| PENDANT/SUPENDED | FP | P | | XP | | |
| WALL | FW | W | | XW | | |
| TRACK | FT | T | | | | |
| TYPE | DESCRIPTION | LAMPS | | VOLTS | WATTS | REMARKS |
| | | NUMBER | TYPE | | | |
| A | 44"Hx18"W CAST ALUMINUM DECORATIVE HID. WALL MOUNTED | 1 | 70 W. M.H. LAMP 5000 LUMENS | 240 | 68W | W/ CAST ALUMINUM WALL BRACKET; CAST ALUMINUM SCROLL AND CAST ALUMINUM WALL MTC. BRACKET |
| PT-1 | 44"Hx18"W CAST ALUMINUM POST TOP DECORATIVE HID. ASYMMETRIC REFRACTIVE PANELS | 1 | 175W M.H. 14,000 LUMEN LAMP | 240 | 220W | 6'-0" POLE |
| PT-2 | 44"Hx18"W CAST ALUMINUM POST TOP DECORATIVE HID. ASYMMETRIC REFRACTIVE PANELS | 1 | 175W M.H. 14,000 LUMEN LAMP | 240 | 220W | 12'-0" POLE |

SUBSTITUTIONS WILL NOT BE ACCEPTED

- 1.) POLE FOR 6'-0" AND 12'-0" SHALL BE HADCO MODEL P2210A FOR THE 6'-0" POLE AND P-2060A FOR THE 12'-0" POLE. THE BRACKET FOR TYPE A SHALL BE HADCO M0211 WITH V211
- 2.) PROVIDE CAST IN PLACE ARCHITECTURAL CONCRETE BASE MANUFACTURED BY ART FORMS. CLASSICA 460R 18" DIA. FOR 6'-0" POLE AND MAROSE 460R (18" DIA.) FOR 12'-0" POLE.